SLIPTEST AUSTRALIA PTY LTD ~ ABN 80 111 154 324

12 Blackbean Court ELANORA QLD 4221 PH 0418 75 3311

SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS AS 4586 (2013) "Appendix A" (Wet Pendulum Method)

Report Prepared For:	Distinctive Tile Imports		Client Address:	485 Zillmere road, Zillmere QLD 4034			
Project:	Vitra M 20 x 20 Maski Dot Mink 861374 R10A VP33						
Property Tested:	Vitra M 20 x 20 Maski Dot Mink 861374 R10A VP33	Date Tested:	03.02.16	Test Report No:	03021614	Issue Date:	04.02.16

Testing was carried out using the Wet Test Method, using Slider 96 (4S) rubber slider, in accordance with Australian Standard AS 4586 Appendix A Slider was conditioned/prepared using P400 abrasive paper and 3 µm lapping film

Number of sites tested 5 / Test location	Test Surface No.	Surface Type	Surface Gradient Degrees	Type and extent of Cleaning Performed	Results of last three swings British Pendulum Number			Mean BPN Test	Slope Correction value (SCV)	Classification of Pedestrian surface materials according to the AS 4586 wet pendulum test	Comments
Tile 1	1	Vitra M 20 x 20 Maski Dot Mink 861374 R10A VP33	<1.5	Water & Scrubbing	43	43	42	43	N/A	P3	
Tile 2	2		<1.5	Water & Scrubbing	43	43	43	43	N/A		
Tile 3	3		<1.5	Water & Scrubbing	44	44	44	44	N/A		
Tile 4	4		<1.5	Water & Scrubbing	44	44	44	44	N/A		
Tile 5	5		<1.5	Water & Scrubbing	47	47	47	47	N/A		

Temperature:	33 °C	Mean BPN Slip Resistance Value (SRV)	44	The above classification is provided without Slope Correction Values
Weather:	Indoors			

Testing Instrument: Munro Portable Skid Tester # 0604 Calibration Date: 19.01.16

Testing Officer & Signatory: JOHN HITCHEN

Fixed Test: Testing is performed in the anticipated direction of pedestrian travel

Unfixed Test : Testing is performed in the direction of least anticipated slip resistance

Sliptest Australia Pty Ltd

Materials Testing Laboratory - Accreditation number 15374
12 Blackbean Court ELANORA QLD 4221

Accredited for compliance with ISO/IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/National standards.

NATA ACCREDITED FOR TECHNICAL COMPETENCE

Notes: