

SLIPTTEST AUSTRALIA PTY LTD ~ ABN 80 111 154 324 12 Blackbean Court ELANORA QLD 4221 PH 0418 75 3311											
SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS AS 4586 (2013) "Appendix A" (Wet Pendulum Method) 485 Zillmere Road, Zillmere QLD 4034											
Report Prepared For:		Client Address:									
Project:		Vitra 30x30 - 861282 Colour Dot Mink R10, BH47									
Property Tested:		485 Zillmere Road, Zillmere QLD 4034		Date Tested:		1/02/2016		Test Report No:			
AO01021612		Issue Date:		2/02/2016							
Testing was carried out using the Wet Test Method, using Slider 96 (4S) rubber slider, in accordance with Australian Standard AS 4586 Appendix A. Slider was conditioned/prepared using P400 abrasive paper and 3 µm lapping film											
Number of sites tested	5	Test Surface No.	Surface Type	Surface Gradient Degrees	Type and extent of Cleaning Performed	Results of last three swings British Pendulum Number		Mean BPN Test	Slope Correction value (SCV)	Classification of Pedestrian surface materials according to the AS 4586 wet pendulum test	Comments
						54	54				
Tile 1		1		<1.5	Water & Scrubbing	54	54	54	N/A		
Tile 2		2	30x30 tiles	<1.5	Water & Scrubbing	54	54	54	N/A		
Tile 3		3		<1.5	Water & Scrubbing	54	54	54	N/A	P4	
Tile 4		4		<1.5	Water & Scrubbing	54	54	54	N/A		
Tile 5		5		<1.5	Water & Scrubbing	55	55	54	N/A		
						Mean BPN Slip Resistance Value (SRV)		54		The above classification is provided without Slope Correction Values	
Testing Instrument: Wessex Portable Skid Tester # 1913		Calibration Date: 14.10.14									
Testing Officer & Signatory: ADAM OLIVER		Sliptest Australia Pty Ltd									
Fixed Test: Testing is performed in the anticipated direction of pedestrian travel		Materials Testing Laboratory - Accreditation number 15374									
Unfixed Test : Testing is performed in the direction of least anticipated slip resistance		12 Blackbean Court ELANORA QLD 4221									
Notes:		Accredited for compliance with ISO/IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/National standards.									

