

<b>SLIPTTEST AUSTRALIA PTY LTD ~ ABN 80 111 154 324</b> 12 Blackbean Court ELANORA QLD 4221 PH 0418 75 3311 <b>SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS AS 4586 (2013) "Appendix A" (Wet Pendulum Method)</b>													
Report Prepared For:		Distinctive Tile Imports								Client Address:	485 Zillmere Road, Zillmere QLD 4034		
Project:		Vitra 40x40- 835954 Dotli Dark Grey R10, BN22								AO02021612	Issue Date:	2/02/2016	
Property Tested:		485 Zillmere Road, Zillmere QLD 4034		Date Tested:		2/02/2016		Test Report No:		AO02021612			
Testing was carried out using the Wet Test Method, using Slider 96 (4S) rubber slider, in accordance with Australian Standard AS 4586 Appendix A. Slider was conditioned/prepared using P400 abrasive paper and 3 µm lapping film													
Number of sites tested	5	Test location	Test Surface No.	Surface Type	Surface Gradient Degrees	Type and extent of Cleaning Performed	Results of last three swings British Pendulum Number			Mean BPN Test	Slope Correction value (SCV)	Classification of Pedestrian surface materials according to the AS 4586 wet pendulum test	Comments
							52	52	52				
Tile 1			1		<1.5	Water & Scrubbing	52	52	52	52	N/A		
Tile 2			2	40X40 Tiles	<1.5	Water & Scrubbing	54	54	54	54	N/A		
Tile 3			3		<1.5	Water & Scrubbing	52	52	52	52	N/A	P4	
Tile 4			4		<1.5	Water & Scrubbing	53	53	53	53	N/A		
Tile 5			5		<1.5	Water & Scrubbing	52	52	52	52	N/A		
							Mean BPN Slip Resistance Value (SRV)			53		The above classification is provided without Slope Correction Values	
Testing Instrument: Wessex Portable Skid Tester # 1913				Calibration Date: 14.10.14		Sliptest Australia Pty Ltd							
Testing Officer & Signatory: ADAM OLIVER				Materials Testing Laboratory - Accreditation number 15374 12 Blackbean Court ELANORA QLD 4221									
Fixed Test: Testing is performed in the anticipated direction of pedestrian travel													
Unfixed Test : Testing is performed in the direction of least anticipated slip resistance													
Notes:													

